



**National Flooring Distributors - SAFE ROAD SHEET VINYL - Wet Sliptest  
BO270220-7**

27 Feb 2020

**Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A**

Date Tested:	27 Feb 2020
Test Report Number:	BO270220-7
Client Name & Address:	National Flooring Direct - 13 Dulwich Street Loganholme Q4129
Test Site / Surface Tested :	SAFE ROAD SHEET VINYL - Cream / Rough
Sample Information :	Samples and Test Information Supplied by Client
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	21
Testing Officer :	Blair Ording
Testing Officer :	Munro-Stanley Portable Skid Tester #0604 - 19.02.2020
Testing Officer Signatory:	

**Test Results :**

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Surface Picture
Area 1A	60	58	57	57	57	57	
Area 1B	60	59	59	58	58	58	
Area 1C	55	55	54	54	54	54	
Area 1D	56	56	55	55	55	55	
Area 1E	55	55	54	54	54	54	

Mean BPN Slip Resistance Value (SRV)

56

CLASSIFICATION using Slider 96 (4S Slider)

P5 = > 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

