

# Emission Test Certificate

Tuesday, 29<sup>th</sup> May 2018

Supplier: Gerflor Australia Pty Ltd (17 Cato St, Hawthorn East, VIC, 3123, Australia)

Sample Description: Gerflor – Texline Comfort.

Date Tested: May 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs exposure):

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design and As Built v1.1 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.1 - 12.1.2B</b></p>	<p align="center"><b>Gerflor – Texline Comfort</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate limit &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.018 mg/m<sup>2</sup>/hr</p>
<p align="center">Formaldehyde Emission Rate limit &lt;0.1 mg/m<sup>2</sup>/hr</p>	<p align="center">Formaldehyde Emission Rate: &lt;0.006 mg/m<sup>2</sup>/hr</p>

***We hereby certify Gerflor – Texline Comfort is below the VOC Emission limits specified by Green Star Design and As Built, Green Star Interiors, Green Building Council of Australia***



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

CV180504a