

Fire Test Certificate

Thursday, 27th December 2018

Supplier: Australian Hardwood Timber Floors & Decking Co
 (103/91 Murphy Street, Richmond, VIC, 3121)

Sample Description: Definitive Hybrid Flooring

Date Tested: December 2018 (Tested by AWTA – NATA Accreditation 1356)

Test Method: AS/ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test results:

AS/ISO 9239-1:2003	Definitive Hybrid Flooring
Critical Heat Flux/Critical Radiant Flux*	10.9 kW/m ²
Smoke Value*	80 %min
Smouldering	N/A
Blistering	Yes
Glowing	N/A

*Three test average value

HF – 30 not reported as flame out time occurred before 30 minutes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Tuan Duong
 BEng (Chemical)
 Consultant

CV180962