

# Dry Slip Test Certificate

Tuesday, 4<sup>th</sup> December 2018

Supplier: Australian Hardwood Timber Floors & Decking Co  
(103/91 Murphy Street, Richmond, VIC, 3121)

Sample Description: Definitive Hybrid Flooring

Date Tested: October 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix B “Slip resistance classification of new pedestrian surface materials – Dry Floor Friction Test Method” using Tortus III with Slider 96.

Test Data:

Sample Identification	Dry floor friction result <sup>1</sup>	Classification <sup>2</sup> (AS 4586-2013 Australian Standards)
Definitive Hybrid Flooring	0.70	D0

<sup>1</sup> Five test average value

<sup>2</sup> The classifications indicate the contribution of the floor surfaces to the risk of slipping when dry is very low



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

CV180962