

Wet Slip Test Certificate

Tuesday, 4th December 2018

Supplier: Australian Hardwood Timber Floors & Decking Co
(103/91 Murphy Street, Richmond, VIC, 3121)

Sample Description: Definitive Hybrid Flooring

Date Tested: October 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: AS/NZS 4586-2013 Appendix A “Slip resistance classification of new pedestrian surface materials – Wet Floor Pendulum Test Method” using Slider 96.

Sample Identification	Wet floor friction result ¹	Classification ² (AS 4586-2013 Australian Standards)
Definitive Hybrid Flooring	45	P4

¹ Five test average value

² The classifications indicate the contribution of the floor surfaces to the risk of slipping when wet is low



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV180962