

Emission Test Certificate

Tuesday, 4th December 2018

Supplier: Australian Hardwood Timber Floors & Decking Co
 (103/91 Murphy Street, Richmond, VIC, 3121)

Sample Description: Definitive Hybrid Flooring

Date Tested: October 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116:2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Interiors V1.1 - 12.1.2B Green Star Design & As Built V1.1 - 13.1.2B	Definitive Hybrid Flooring
Total Volatile Organic Compound Emission Rate Limit: $<0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.012 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $<0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.041 \text{ mg/m}^2/\text{hr}$



Photo of tested specimen



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV180962