

Dimensional Stability Test Certificate

Thursday, March 21th, 2019

Supplier: Australian Hardwood Flooring & Decking Co (103/91 Murphy Street, Richmond VIC 3121)

Sample Description: Definitive Hybrid Flooring

Date Tested: 05 March 2019 (Tested by Foray laboratories – NATA Accreditation 1231)

Test Method: ISO 23999:2018 Resilient floor coverings “Determination of dimensional stability and curling after exposure to heat at 80°C for 6 hrs”.

Test Data:

Dimensional Stability Linear Change (%)				Allowable Tolerances As Per EN ISO 10582 Standards
Grain Direction		Across Grain Direction		
Mean	Maximum	Mean	Maximum	≤ 0.40 %
0.15	0.17	0.05	0.11	
Curling (mm)				≤ 8.0 mm
Mean Initial		Mean Final		
0.5		0.5		

CV190283

Photo of tested samples



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B. Eng. (Chemical)
Consultant

CV190283